



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

March 30, 2009
Subject: **Dallas Plantation**
State Pin No. 015969.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: What are the concrete specifications (i.e. class) for the Box Culvert?

Response: In accordance with Special Provision, Section 534, the Contractor shall submit design calculations and shop drawings for approval. Concrete shall meet the requirements of the approved shop drawings as well as Standard Specification, Section 712.061 Structural Precast Concrete Units and Special Provision, Section 534.

Consider this information prior to submitting your bid on April 1, 2009.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER

THE MAINE DEPARTMENT OF TRANSPORTATION IS AN AFFIRMATIVE ACTION - EQUAL OPPORTUNITY EMPLOYER